

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No. F.6/DFS/MS/School/2025/SZ/ 1360

Dated: 28/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Shiv Vani Model Senior Secondary School located at Mahavir Enclave, Palam-Dabri Road, Dwarka, New Delhi- 110075, comprised of small basement (closed), ground floor plus three upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/SZ/2022/834 dated 02.08.2022. The school building was re- inspected by the officer concerned of this department on dated 17.11.2025 in the presence of Mr. Atul Arora (Owner), and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus three upper floors) is fit for occupancy class "Educational Building" w.e.f. 28/11/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 28/11/2025 at New Delhi by.


 (A. K. Malik)
 Dy. Chief Fire Officer
 South Zone
 26/11/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The HOS. Shiv Vani Model Senior Secondary School located at Mahavir Enclave, Palam-Dabri Road, Dwarka, New Delhi- 110075.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Shiv Vani Model Sr. Sec. School at Mahavir Enclave,
Palam- Dabri Road, Dwarka, New Delhi- 110045.
2. Building comprised of : Ground plus three upper floors with small basement (closed).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/SZ/2022/834 dated 02.08.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 17.11.2025
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Atul Arora (Owner)
10. Year of Construction : 1995
11. Applicant's letter No. : SVMS/DFS(Compliance)/2025/11246 dated 31.10.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 02.08.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	Provided Provided N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	07 No's	GF to terrace- 05, GF to SF- 01, FF to 3 rd Floor- 01	M/R
	<ul style="list-style-type: none"> Basements 	02 No's	02 No's	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.50 m & if less than addl. Stair of 0.75 m	1.40, 1.093, 0.89, 1.05, 1.04, 1.29 & 1.30 m	MR, old case
	<ul style="list-style-type: none"> Basements 		1.42 & 1.40 m	MR, old case
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	05 nos.	M/R
	e. Width of Corridor	1.50 m	Provided	M/R
	f. Door Size	1.0 m	1.0m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required	Exhaust fan Provided	MR
		Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	45 no's ABC/CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			Provided	M/R
6.	First-Aid Hose Ree			
	<ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter 	04 nos. 30 M 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R

N/23

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		900 LPM	3 × 450 LPM	MR
		40 m.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	75,000 ltrs.	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		15,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	No Lift			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

N/24

N/A	17.	Standby power supply	Required	Provided (DG Set)	MR
V/A	18.	Refuge Area.			
		➤ Total Area	N/A	N/A	N/A
		➤ Location	N/A	N/A	N/A
	19.	Fire Control Room			
		• Detector System Panel	N/A	N/A	N/A
		• Flow Switch Panel	N/A	N/A	N/A
		• PA System Panel	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
		• Building Floor Plans	N/A	N/A	N/A
	20.	Special Fire Protection System for Protection of special Risks, if any:	Required	ABC type Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/760 dated 03.10.2025 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/SZ/2022/834 dated 02.08.2022, is **recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

R.K. Yadav
 Signature of the Inspecting Officer
 Name:-R.K. Yadav
 Designation: - ADO (DWK)

DO/SW) *[Signature]*
 20/11/25
 RAJINDER ATWAL

Dy. CPO (SZ)
[Signature]
 21/11/25
 A.R. MALIK

Principal Officer
[Signature]
 Dy. CPO (SZ)
[Signature]

Dy. CPO to J.S.M.
[Signature]
 21/11/25

[Signature]
 24/11/25
 A.R. MALIK

DO/SW)
[Signature]
 24/11
 ADO - ofr