

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2026/NZ/593

Dated: 29/06/2026

To,

The Principal,
Shivalik Little kingdom,
9A, 100 feet road,
West Sant Nagar, Burari, Delhi.

Sub:- Issuance of Fire Safety Certificate in respect of Shivalik Little kingdom
at 9A, 100 feet road, West Sant Nagar, Burari, Delhi.

Sir,


This has reference to your letter received through outdoor diary no. 1689 dated 29/05/2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.06.2026 to see the compliance of the requisite fire safety measures. Mr. Nitin was present at the time of inspection.

Your request for issuance of FSC is rejected due to the following shortcomings: -

1. Width of both the staircases found 1.2 m and 1.5 m against the required width of 1.5 m each.
2. There is only one staircase reaches up to the terrace against the requirement of both the staircases shall reach up to the terrace.
3. Terrace level pump not found in auto mode.
4. Exit signage's not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully



(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.