

C-95

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2025/SZ/144

Dated: 03/04/2025

To,

The Joint C.P. (LIC.),
1st floor, Police Station,
Defense Colony, New Delhi.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o M/s Shivam Foods at C-2, B-79, GTK Road, Industrial Area, New Delhi.

Sir,

Please refer to online application ID 2025030602903 dated 06.03.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid eating house building on dated 27.03.2025 in presence of Sh. Manish Tiwari (Manager), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the above said eating house/restaurant running at ground, 1st & 2nd floor only in a building comprised of basement (storage) ground plus two upper floors. Earlier, this department issued a FSC to aforesaid eating house vide letter No. F.6/DFS/MS/EH/SZ/2022/05 dated 12.01.2022 for ground and 1st floor only but now eating house management has applied for ground, first & second floor, and following shortcomings observed: -

1. Two staircases having width of 1.50 m each found provided upto 1st floor and one staircase with width of 1.50 m provided at 1st floor to 2nd floor. Both staircases should be extended upto terrace floor.
2. Hose reels & hydrants system should be provided upto 2nd floor.
3. Terrace fire pump capacity of 900 LPM found provided but not functional in auto mode.
4. PA system is to be provided.
5. Overhead water tank is provided 10,000ltr against the requirement of 20,000ltr.
6. Exit Signages found removed at some places.

Keeping in view of above, issuance of fire safety certificate can-not be considered at this stage. Management of the restaurant may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department and running restaurant/eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy for information: -

1. The Owner/Occupier, M/s Shivam Foods at C-2, B-79, GTK Road, Industrial Area, New Delhi.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi