



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2026/SZ/ 365


Dated: 16/04/2026



FIRE SAFETY CERTIFICATE

Certified that M/s Jubilant Food Works Limited Domino's Pizza located at Shop No. 113B, 114B & 130, Sewak Park, Dwarka Mor, New Delhi-110059, **running at ground floor only** in a building comprised of basement, ground plus three upper floors, owned/occupied by M/s Jubilant Food Works Limited Domino's Pizza, was issued FSC by this department vide letter No. F6/DFS/MS/EH/SZ/2023/184 dated 13/06/2023. The premise was re-inspected by the officer concerned of this department on 06/04/2026 in the presence of Mr. Dharmendra (Manager) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "Assembly Group D" (**Restt. at ground floor only**) with effect from 16/04/2026 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/04/2026 at New Delhi by


(A.K. Malik)
Chief Fire Officer (SZ)
Delhi Fire Service


Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi-110002 (w.r.t. online Id. No. 2026032303400 dated 23/03/2026)
2. Mr. Yunus Khan, M/s Jubilant Food Works Limited Domino's Pizza, Shop No. 113B, 114B & 130, Sewak Park, Dwarka Mor, New Delhi-110059

Conditions for the validity of Fire Safety Certificate:

1. This FSC is issued and valid for restaurant at ground floor only.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-5

INSPECTION REPORT

1.	Name & address of the building	M/s Jubilant Food Works Ltd. (Domino's Pizza), Prop. No. 113B, 114B and 130, GF, Sewak Park, Dwarka Mor, Delhi-110059		
2.	Type of Occupancy	Group 'D' (Assembly)		
3.	Building Comprised of	Basement, ground + three upper floors but the restaurant is running at ground floor only.		
4.	Type of Case	Renewal		
5.	Details of previous FSC No.	F6/DFS/MS/EH/SZ/2023/184 dt 13/06/2023		
6.	Fire safety directives letter No.	Nil		
7.	Date of inspection	06/04/2026		
8.	Name of the Inspecting Officer	ADO (JKP)		
9.	Name and designation of Officer from the building side	Mr. Dharmendra (Manager)		
10.	Year of Construction	2000		
11.	Applicant's letter No./Online Appn.	No. 2026032303400 dated 23/03/2026		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	N/A	Directly accessible	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits	Restaurant is running at ground floor only		
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 x 1.5m	2.0m, 1.55m & 0.90m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	N/A	N/A	N/A
	• Ground floor.	12 ACPH	Exh. Fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

JK

N-6

7.	Automatic fire detection and alarming system.			
	- Type of detector - Location of Main Panel - Location of Repeater Panel - Alternate source of power - Hooters' Location	Smoke / Heat	Provided	MR
		Required	Near reception	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	- Basements - Upper floors. - Sprinkler above false ceiling	N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	- Size of riser/down-comer - Number of hydrants. - Hose Box	100 mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12.	Yard Hydrants			
	- Total number of hydrants - Hose Box	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	Ground Level			
	➤ Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	Terrace level			
	➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump	450 LPM	Provided	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for firefighting			
	- Underground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank - Overhead Tank capacity	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		20,000 ltr	Provided	MR
15.	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge area			
	➤ Total area ➤ Location	N/A	N/A	N/A
		N/A	N/A	N/A

SR

N-7

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	ABC type fire extinguishers provided near elect. panel	MR

The fire protection systems provided in the building/premises were checked, tested at random and **found functional at the time of inspection.**

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/EH/SZ/2023/184 dated 13/06/2023, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval and signature please.

Date of deemed/auto approval: 21/04/2026


Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (JKP)

DO (SW)

8/4/26
RAJINDER ATWAL
D.F.S (SZ)


9/4/26
A.K. MALIK
Principal Director


my. CFO (SZ)

my. CFO to Issue.

08/04/26


10/4/26
A.K. MALIK
DO (SW)


11/4
ADO (JKP) SK

P.F.D