



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2026/21

Dated: 16.01.2026

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Minto Road,
New Delhi.

Sub:- **Rejection** of building plans from fire safety point of view in r/o Mercantile Occupancy at Shop No. 2, Defence Colony Market, New Delhi.


Sir,

With reference to request ID no. 10121507 dated 06.01.2026 on the subject cited above; it is informed that the referred online building plans in respect of Mercantile Occupancy at Shop No. 2, Defence Colony Market, New Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. Width of staircase 1.5 meter each are not proposed as per clause 7.11 of UBBL-2016/NBC-2016, Part-IV.
2. Fire prevention & fire safety measures are not proposed as per NBC-2016, Part-IV/UBBL-2016.

In view of the above, the building plans are **rejected** with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully,


(M. K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service