




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/SW/2025/ 200

Dated: 19/05/2025

FIRE SAFETY CERTIFICATE

Certified that M/s Mishtanam (A unit of Dulari Foods) located at ground floor of Shop No. 3-35, 3-33 GF, Main Najafgarh Road, Tilak Nagar, Delhi-110018 in a building comprised of Ground + 02 upper floors, ground floor owned/ occupied by Dulari Foods(M/s Mishtanam) have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned from this department on 10.05.2025 in the presence of Mr. Praveen Kumar and found that the said premises is fit for occupancy class "Assembly" Group D (**Ground Floor only**) with effect from 19/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on ...19/05/2025.. at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy as detailed above and duration if any. Online ID no. 202350507666 dated 01.05.2025
2. The Add. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
3. The Manager, M/s Mishtanam (A unit of Dulari Foods) located at Shop No. 3-35,3-33 GF, Main Najafgarh Road, Tilak Nagar, Delhi-110018

CONDITIONS FOR VALIDITY OF FIRE SAFETY CERTIFICATE

1. This Fire Safety Certificate is valid for Ground Floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy/use, electric installation etc. shall be got verified and approved from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This Fire Safety Certificate shall not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N-1

INSPECTION REPORT

1	Name & address of the building	M/s Mishtanam (A Unit of Dulari Foods) at Shop No. 3-35, 3-33 GF, Main Najafgarh Road, Tilak Nagar, Delhi-110018			
2	Building is comprised of	Ground + 02 upper floors (running at ground floor)			
3	Type of occupancy	Group D – Assembly Building			
4	Type of case	New case			
5	Details of previous FSC	Nil			
6	Fire safety directive letter no.	N/A			
7	Date of inspection	10.05.2025			
8	Name of the inspecting officers	Suman Kumar, ADO			
9	Name of the designation of officer From the building side	Sh. Praveen Kumar, Manager			
10	Year of construction	2000			
11	Applicant's letter no.	Online ID no. 202350507666 dated 01.05.2025			
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (as per the issued guideline) NBC/UBBL-2016	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	6.0 m	Provided	MR
	B	Gate width	4.5 m	Directly accessible from road	MR
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	NA	NA	NA
		b) Basements	NA	NA	NA
	B	Width of the staircase:			
		a) Upper floors	NA	NA	NA
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	NA	NA	NA
	E	Width of the corridor	NA	NA	NA
	F	Door size	3 X 1.5	Provided	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	Required	Natural ventilation	MR
5	Fire Extinguishers				
	A	Total numbers	04 nos.	Provided	MR
	B	Types	CO ₂ & ABC	Provided	MR
	C	ISI marking	ISI marked	Provided	MR

N-2

6	First Aid Hose Reel				
	A	Total no. at each floor	01 no.	Provided	MR
	B	Length of hose reel	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of detectors	NA	NA	NA
	B	Location of main Panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA				
		Required	NA	NA	NA
9	Public Address System				
		NA	Provided	NA	MR
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants				
	A	Size of the riser/down comer	100 mm	Provided	MR
	B	No. of hydrants per floor	01 no.	Provided	MR
	C	Hose box	01 no.	Provided	MR
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of Standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	Provided	MR
		b) Head of terrace pump	40 m	Provided	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting Terrace level				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	20,000 Ltrs	Provided	MR
15	Exit Signage				
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	Provided	MR
17	Standby Power Supply				
		Required	NA	NA	NA

N-3

18	Refuge Area				
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA
19	Fire Control Room				
	A	Fire detection system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	P A system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any				
	A	Special fire protection system for protection of special risk, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards on fire safety required under the rules, it is recommended to grant Fire Safety Certificate under Rules 35 of Delhi Fire Service Rules 2010.

Suman Kumar
14/05/2025
Signature of the Inspecting Officer
Name - Suman Kumar
Designation ADO

D.O (DO)
14/5/25

CFO
15/5/2025
Director
16/5/21
17/5/21

F.T. letter is put up for signature by

Director
19/5/21

19/05/2025

Unloaded
21/5/25