

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI- 110001

No. F6/DFS/MS/EH/2025/SZ/ 152

Dated: 07/04/2025

To,

The Joint C.P. (LIC.), 1st floor, Police Station, Defense Colony, New Delhi.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o M/s Jubilant FoodWorks Limited Domino's Pizza located at Shop No. 3, UGF, Shahdara Metro Station, New Delhi-32.

Sir,

Please refer to online application ID 2025031103310 dated 11.03.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid eating house building on dated 28.03.2025 in the presence of Sh. Narayan Pandey, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the above said eating house/restaurant running at upper ground floor only in a building comprised of lower ground floor and upper ground floor, and have following shortcomings: -

1. Terrace fire pump capacity of 450 LPM provided but found common with Burger King restaurant. A separate terrace fire pump capacity of 450 LPM should be provided.

2. Overhead water storage tank capacity of 20,000 ltrs. provided but found common with Burger King restaurant. A separate water storage tank capacity of 20,000 ltrs should be provided.

3. Exit Signages found not provided.

Keeping in view of above, issuance of fire safety certificate can-not be considered at this stage. Management of the restaurant may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department and running restaurant/eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

ul Garg) Director

Copy for information: -

The Owner/Occupier, M/s Jubilant FoodWorks Limited Domino's Pizza located at Sho No. 3, UGF, Shahdara Metro Station, New Delhi- 110032.