

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2025/SZ/220  
To

Dated: 19/05/2025

The Addl. Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049

**Sub: -** Regarding issuance of fire safety certificate in r/o M/s Jubilant Food Works Ltd (Domino's Pizza) at Ground Floor, Shop No G-40, Vikas Cine Mall, Shahdara Delhi 110032.

Sir,

This has reference to your **MCD Portal ID 2025042407065** dated **24/04/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.03.2025 in the presence of Ms. Nisha (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of 02 Basement, Ground plus 04 upper floors and restaurant is running at ground floor only. During inspection, following points were observed:

- 1 Terrace level fire fighting pumps capacity 450 LPM found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE