



C13



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/GH/2026/NDZ/ 92

Dated: 29/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s **Shree Balaji Inn Guest House** located at 11, 1262, Nalwa Katra Baryan, Fatehpuri, Delhi, New Delhi-110055, comprised of Ground plus three upper floors, **Ground floor (Reception + 07 guest room+ Parchatti for staff), 1st floor (11 guest rooms), 2nd floor (11 guest rooms) & 3rd floor (07 guest rooms)** Total 36 guest rooms was granted FSC by this department vide letter no. F.6/DFS/MS/GH/NDZ/2022/369 dated 02/08/2022 Now, the building /premises was re-inspected by the officer concerned of this department on 08/01/2026 in the presence of Sh. Om Prakash Bansal and found that the building comprised is **Ground floor (reception + 07 guest room + Parchatti for staff), 1st floor (11 guest rooms), 2nd floor (11 guest rooms) & 3rd floor (07 guest rooms)** the building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Residential" (Group A-1) **Ground floor (07 guest room), 1st floor (11 guest rooms), 2nd floor (11 guest rooms) & 3rd floor (07 guest rooms)** Total 36 guest rooms only with effect from 29/01/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....29/01/2026.....at New Delhi by

(Dr. S. K TOMAR)
DY. CHIEF FIRE OFFICER
DFO DELHI FIRE SERVICE

To,

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. M/s Shree Balaji Inn Guest House located at 11, 1262, Nalwa Katra Baryan, Fatehpuri, Delhi, New Delhi-110055

MCD online ID 2025122316011

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s Shree Balaji Inn Guest House
11, 1262, Nalwa Katra Baryan, Fatehpuri, Delhi, New Delhi-110055.

2. Type of Occupancy : Residential, Sub Division-A-1

3. Building is comprised of : Ground plus three upper floors (total 36 Guest rooms)
Ground floor (Reception + 07 guest room), 1st floor (11 guest rooms), 2nd floor (11 guest rooms) & 3rd floor (07 guest rooms)

4. Type of Case : Renewal

5. Details of Previous NOC letter : F.6/DFS/MS/GH/NDZ/2022/369 dated 02/08/2022

6. Fire Safety directive letter No : N/A

7. Date of Inspection : 08/01/2026

8. Name of the Inspecting officers : ADO (Shahdara), Deepak Kumar

9. Name and designation of Officer from the building side : Sh. Om Prakash Bansal

10. Year of Construction : 1993

11. Applicant's letter No : 2025122316011 dated 23/12/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement Existing fire safety arrangements	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases <ul style="list-style-type: none"> • Upper Floor • Basement B. Width of Staircases <ul style="list-style-type: none"> • Upper Floor • Basement c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door Size	01 nos. N/A 01 mtr. N/A Required N/A 01 nos N/A 0.80 mtr.	01 nos. N/A 01 mtr N/A Provided N/A 01 nos N/A 0.80 mtr.	MR N/A MR old case N/A MR N/A MR N/A MR old case
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A Required	N/A Natural ventilation	N/A MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	11 nos. ABC /CO ₂ Required	11 nos. ABC /CO ₂ Provided	MR MR MR

11/43

06	First-aid-Hose Reels.				
	Total numbers on each floor • Length of hose reel hose • Nozzle diameter	01 No.	01 No	MR	
		30 mtr.	30 mtr.	MR	
		05 mm	05 mm	MR	
07	Automatic fire detection and alarming system.				
	• Type of detectors CO • Location of main panel • Location of repeater panel • Alternate source of power • Hooter's location	Required	Provided	MR	
		Gr. floor	Provided	MR	
		N/A	N/A	N/A	
		Required	Provided	MR	
	Gr. floor	Provided	MR		
		N/A	Provided	N/A	
08	MOEFA	N/A	Provided	N/A	
09	Public address System.	Required	Provided	MR	
10	Automatic Sprinkler System.				
	• Basement • upper floor • sprinkler above false ceiling	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
11	Internal Hydrants				
	• size of riser/down-comer • Number of hydrants per floor • Hose Box	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
12	Yard Hydrants.				
	• Total number of hydrants • Hose Box	N/A	N/A	N/A	
		N/A	N/A	N/A	
13	Pumping Arrangements.				
	• Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		225 Lpm.	225 Lpm.	MR	
		30 mtr	30 mtr	MR	
	• Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity	Required	Provided	MR	
		Required	Provided	MR	
14	Captive Water Storage for Fire Fighting.				
	• Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		2,500 Ltr.	2,500 Ltr	MR	
15	Exit Signage.	Required	Provided	MR	
16	Provision of Lifts.	N/A	N/A	N/A	
	• Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift car • Firemen's grounding switch • Lift Signage	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	


2144.

		Required	Provided	MR
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter no. F.6/DFS/MS/GH/NDZ/2022/369 dated 02/08/2022, **renewal under Rule 37 of the Delhi Fire Service Rules 2010, is recommended.**


Last Date:- 21/01/2026



P8/01/2026
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shd./TP)

DO (CD)



16/01/26



Dy. CFO (NDZ)


Dy. CFO (NDZ)
21/01/26


Principal Director


M. CFO to Dm.
21/01/26



M. CFO to Dm.
21/01/26



ADO/Stat.
21/01/26

on 21.

1/1

Sir, F.T. letter is put up for your kind
Signature pl.


Dy. CFO (NDZ)


Deepak
26/01/2026