



No. F6/DFS/MS/School/NDZ/2025/ 609

Dated: 06/05/2025

FIRE SAFETY CERTIFICATE

Certified that Shree Ram Vidya Mandir School located at Shri Siddh Hanuman Mandir, Manadawali Fazalpur, Delhi - 110092, building comprised of ground plus three upper floors, But school running on ground plus two upper floors only owned/ occupied by Shree Ram Vidya Mandir School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/NDZ/2185 dated 25/09/2018. The school building was re-inspected by the officer concerned of this department on 22/04/2025 in presence of Mr. A. K. Panday (Principal) of the school and found that the school building having given an affidavit dated 16.04.2025 regarding not to use any floor above two floor deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education and that the building is fit for occupancy class (Group - B) "Educational Building" for ground plus two upper floor only with effect from 06/05/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 06/05/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

OK DELHI FIRE SERVICE

Copy to: -

1. The Director of Education (GNCT), Old Secretariat, Civil Lines Delhi - 110054.
2. The Principal, Shree Ram Vidya Mandir School located at Shri Siddh Hanuman Mandir, Manadawali Fazalpur, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. This fire safety certificate is valid for Ground plus two upper floors.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

-N/14-

INSPECTION REPORT

1	Name & address of the building	Shree Ram Vidya Mandir School located at Shri Siddh Hanuman Mandir, Manadawali Fazalpur, Delhi - 110092		
2	Building is comprised of	Ground plus three upper floors. (But school running on ground plus two upper floors only as per affidavit dated 16/04/2025)		
3	Type of occupancy	Educational Building		
4	Type of case	Addition/Alteration		
5	Details of previous FSC	F6/DFS/MS/School/2018/NDZ/2185 dated 25/09/2018 (G+2 floors)		
6	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7	Date of inspection	22/04/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. A. K. Panday (Principal)		
10	Year of construction	1974		
11	Applicant's letter no.	Outdoor Diary No. 14865 dated 24/03/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building:			
	A Road width	6.0 meters.	4.0 meters.	MR (old case)
	B Gate width	4.5 meters.	4.5 meters.	MR
	C Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	1 no.	2 nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 meters	1.05 meters & 1 mtrs	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	1 no.	1 no.	MR
	E Width of corridor	1.50 meters	1.50 meters	MR
	F Door size	1.0 meter.	1.0 meter.	MR
3.	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A


5. Fire Extinguisher:					
	A	Total numbers	06 nos.	06 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	01 no	01 no	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	Provided	MR
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1 Ground level					
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2 Terrace Level					
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 ltrs	10,000 ltrs
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

Note: - At the time of inspection 3rd floor found closed given an affidavit dated 16/04/2025.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/NDZ/2185 dated 25/09/2018 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO/Laxmi Nagar

D.O./EAST

DFA Phase

By C.F.O. (NDZ)
C.F.O.
24/4/2025
25/04/25

28/4/2025
Director
29/04/25

AD/LN

R.T.O