



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Bnqt/2025/NDZ/ 146

Dated: 19/08/2025

To

The Commissioner,
Municipal Corporation of Delhi,
8th Floor, Civic Centre, JLN Marg,
Minto Road, New Delhi-110002

Sub: Renewal of Fire Safety Certificate in r/o **Shree Shyam Palace** (Banquet Hall) located at GF & FF, PD Area of Mansarovar Park Metro Station, Delhi-110032

Sir,

This is with reference to online application No. **2025072111677** dated 26/07/2025. In this connection, it is informed that the aid banquet hall was inspected by the officers concerned of this department on 01/08/2025 from fire & life safety point of view, in the presence of Mr. Pankaj (Manager). During course of inspection, **the shortcomings observed is as below.**

1. Smoke/Fire Check Doors found removed.
2. Automatic detectors found non-functional.
3. Exit signage's found removed at some places in escape route.

In view of the above non-compliance, application for **renewal of fire safety certificate cannot be considered at this stage & rejected**. The occupancy of the building/premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

01/08/25

Copy to: -

1. Nodal Officer, Delhi Fire Service with the request to upload on online portal.