

cl95

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/Hospital/2025/SZ/ 368

Dated: 03/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Shri Daya Dutt Vashist Hospital (Multi Speciality Hospital)** at J-34, Ganga Ram Vatika, Near Raj Cinema, Chowkhandi, Tilak Nagar, New Delhi-110018, comprised of basement, stilt (parking), ground plus three upper floors owned/occupied by **Shri Daya Dutt Vashist Hospital**, was issued FSC by this department vide letter No. F.6/DFS/MS/Hospital/2022/SZ/03 dated 03.01.2023, The Hospital building was re-inspected by the officer concerned of this department on 11.06.2025 in the presence of Dr. Sanjeev Vashist, and found that Hospital building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class **Group-C "Institutional Building"** wef 03/07/2025 for a period of **03 years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.
Issued on 03/07/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
07/07

Copy to: -

1. The Commissioner, MCD, Delhi: for information regarding use of basement and to ensure the occupancy as detailed above and deviation, if any.
2. The Authorized Signatory, Shri Daya Dutt Vashist Hospital (Multi Speciality Hospital) at J-34, Ganga Ram Vatika, Near Raj Cinema, Chowkhandi, Tilak Nagar, New Delhi-110018.
3. The MS, Nursing Homes, Directorate of Health Services, Govt. of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/22

INSPECTION REPORT

1. Name & address of the building : Shri Daya Dutt Vashist Hospital (Multi Speciality Hospital) at J-34, Ganga Ram Vatika, Near Raj Cinema, Chowkhandi, Tilak Nagar, New Delhi-18.
2. Building is comprised of : Basement, stilt, ground floor plus three upper floors.
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/Hospital/2022/SZ/03 dated 03.01.2023
6. Fire Safety directives letter No : Nil
7. Date of inspection : 11.06.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Dr. Sanjeev Vashist
10. Year of Construction : 1997-98 & 2004-05
11. Applicant's letter No. : SDDVH/2025/964 dated 02.06.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33.	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 M N/A N/A	Provided N/A N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 nos. 02 nos.	02 no.'s + ramp 01 no.'s +1 ramp	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	2 m & 1.50 m 2 m & 1.0 m	2.0 m, 1.0 m & 1.88 ramp 2.90 m ramp & 1.0 m stair	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	one	Provided	M/R
	e. Width of Corridor	1.5 M	1.70/1.5m	M/R
	f. Door Size	1.0 m	1.08 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required N/A N/A N/A	Provided Sealed N/A N/A N/A	MR M/R N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Provided Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 no.'s ABC/ CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 No. 30 m 5 mm	Provided Provided Provided	M/R M/R M/R

N/23

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	M/R
		N/A	Ground floor	M/R
		N/A	Ground floor	M/R
		Required	Provided	M/R
		Required	Provided	M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		one	Provided	MR
		one	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	1620 LPM	Provided	MR
		60 m	Provided	MR
		one	Provided	MR
		180 LPM	Provided	MR
		60 m	Provided	MR
		1620LPM	Provided	MR
		60 m.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 ltrs.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	M/R
		Required	Provided	MR

N/24

	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Fire extinguishers provided nearby electrical panel	MR

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/Hospital/2022/SZ/03 dated 03.01.2023, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.

R. K. Yadav
 25/6/2025
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

~~DO (SW)~~

R. K. Yadav
 26/6/25

CFO
 30/6/2025

Director
 11/7/21

ADP
 R-T letter to put up for sign please
R. K. Yadav
 23/7/2025
 DIRECTOR
 N