



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No.F6/DFS/MS/School/2025/NDZ/ 1195

Dated: 26/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that Shri Goverdhan Vidya Niketan located at 62/4, Balbir Nagar Extn. Shahdara, Delhi 110032, comprised of Ground plus one upper floor but school is running ground floor only, owned/occupied by Shri Goverdhan Vidya Niketan was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/694 dated 23/06/2022. The premises was re-inspected by the officer concerned of this department on dated 11/09/2025 in the presence of Sh. Vishnu Dutt Sharma, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' (Ground floor only) with effect from 26/09/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 26/09/2025 at New Delhi by

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER

To,

The Manager

Shri Goverdhan Vidya Niketan located at 62/4, Balbir Nagar Extn. Shahdara, Delhi 110032

Copy:-

The Director of Education, MCD

15<sup>th</sup> Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate**

1. FSC is valid for ground floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/14.

1. Name & address of the building : Shri Goverdhan Vidya Niketan,  
62/4, Balbir Nagar Extn. Shahdara, Delhi 110032
2. Building is comprised of : Ground plus one upper floors  
(School is running on ground floor only)
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/694 dated 23/06/2022
6. Fire Safety direction letter No : Circular 2011 issued by DoE
7. Date of Inspection : 11/09/2025
8. Name of the Inspecting officers : ADO (Shahdara), Deepak Kumar
9. Name and designation of Officer  
from the building side : Mr. Vishnu Dutt Sharma, Manager
10. Year of Construction : 1983
11. Applicant's letter No : Email:-vishnudatt1959@gmail.com dt- 09/09/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	03 nos.	04 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR



2/15


06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.			

P/16

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:			

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter no. F.6/DFS/MS/School/2022/NDZ/694 dated 23/06/2022 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

 11/09/2025  
Signature of the inspection Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (Shd)

~~DO(ED)~~ DFA Please.  
1  
Apparal  
17/09/2025  
Kiv  
17/09/25  
C.F.O.  
22/9/2025

Principal Director

@fo to Sam.

22/09/25

CFO

22/9/2025

Ado (Shah)