

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/BNQT/2025/135
To

Dated: 29/07/2025

The Addl. Commissioner of Police,
Lic Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Shri Govindam Gopala Hall (A Unit of Gokul Garden Banquets Pvt Ltd) at WZ 306 Second Floor, Kh. No 72/6/1 Ghotiyal Palam Village Delhi 45


Sir,

This has reference to with **MCD Portal ID 2025070110758 dated 01/07/2025** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.07.2025 in the presence of Mr. Sanjay Solanki to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 MOEFA provided but found not working.
- 2 Kitchen running at terrace level is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. MCD Portal ID 2025070110758 dated 01/07/2025 for uploading.