

d/21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No:F6/DFS/MS /NDZ/2025/ 440

Dated: 20/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Shri Guru Jambheshwar Sansthan Bhawan** located at **Inner Ring Road, Near I.P. College, Civil Lines, Delhi - 110054**, comprised of **Basement + Ground + 03 upper floors** owned/ occupied by **Shri Guru Jambheshwar Sansthan Bhawan** was granted FSC by this department vide letter No. **F6/DFS/MS/NDZ/2018/2088** dated **12.09.2018**. This premise was re-inspected by the officer concerned of this department on 06.08.2025 in the presence of Mr. Mahavir (Manager) and observed that the said building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that **the premises is fit for occupancy class "Residential Building" with effect from 20/08/2025 for a period of three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 20/08/2025 at New Delhi by


19/08/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02.
2. The President, Shri Guru Jambheshwar Sansthan Bhawan, Inner Ring Road, Near I.P. College, Civil Line, Delhi - 110054.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	Shri Guru Jambheshwar Sansthan Bhawan at Inner Ring Road, Near I.P. College, Civil Lines, Delhi - 110054.
2.	Type of occupancy with details of floors:	Residential Building (Basement + Ground + 03 upper floor)
3.	Type of case:	Renewal
4.	Details of previous NOC:	F6/DFS/MS/NDZ/2018/2088 dated 12.09.2018
5.	Fire safety directives no.:	NA
6.	Date of inspection:	06.08.2025
7.	Name of the inspecting officer:	ADO (SPM)
8.	Name and designation of the officer from the building side:	Mr. Mahavir (Manager)
9.	Year of construction:	
10.	Reference letter no.:	Letter outdoor diary no. 4330 dated 30.07.2025

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (as per NOC dated 12.09.2018)	Provided at site	Remarks MR/NMR
1	Access to Building			
	A Road width	09 mtr	12 mtr.	MR
	B Gate width	05 mtr.	05 mtr.	MR
	C Width of internal roads	03 mtr.	06 mtr.	MR
2	Number, Width, Type & Arrangement of Exits			
	A No. Of Staircase:			
	a) Upper Floor	02 nos.	02 nos.	MR
	b) Basements	02 nos.	02 nos.	MR
	B Width of the Staircase:			
	a) Upper floors	1.25 mtr.	1.5 mtr. each	MR
	b) Basements	1.25 mtr.	1.5 mtr. each	MR
	C Protection of Exits			
	a) Fire Check Door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D No. Of continuous staircase to terrace:	01 no.	02 nos.	MR
	E Width of the corridor	1.25 mtr.	1.25 mtr.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire Check doors	NA	NA	NA
	Sealing of Electrical Shafts	Required	Provided	MR
	B Fire rating of shaft Doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke management System:			
	A Basements	12 ACPH	Exhaust fans	MR
	B Upper floors	12 ACPH	Natural	MR
5	Fire extinguishers			
	A Total numbers	20 nos.	20 nos.	MR
	B Types	CO2 , ABC	Provided	MR
	C ISI marking	Required	Provided	MR

6	First Aid Hose reel				
	A	Total no. at each floor	01 no.	01 no.	MR
	B	Length of Hose Reel	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS):				
	A	Type of Detectors	Required	Provided	MR
	B	Location of main Panel	At entrance	Provided	MR
	C	Location of Repeater Panel	Each floor	Provided	MR
	D	Alternate power Source	Required	Provided	MR
	E	Hooter's location	Each floor	Provided	MR
8	MOEFA		NA	Provided	NA
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	Required	Provided	MR
	B	Upper Floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	100 mm	100 mm	MR
	B	No. Of hydrants per floor	01 no.	01 no.	MR
	C	Hose box per floor	01 no.	01 no.	MR
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	2280 LPM	2280 LPM	MR
		b) Head of main pump	60 m	60 m	MR
		c) Number of main pump	01	01	MR
		d) Discharge of jockey pump	180 LPM	180 LPM	MR
		e) Head of jockey pump	60 m	60 m	MR
		f) Discharge of Diesel Standby pump	2280 LPM	2280 LPM	MR
		g) Head of Standby pump	60 m	60 m	MR
		h) Auto starting/ manual stopping	Required	Provided	MR
	B	Terrace Level			
		a) Discharge of terrace pump	900 LPM	900 LPM	MR
		b) Head of terrace pump	30 mtr.	30 mtr.	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	50,000 ltrs.	50,000 ltrs.	MR
	B	Draw off connection	Required	Provided	MR
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	20,000 ltrs.	20,000 ltrs.	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply		Required	Provided	MR

18	Refuge Area			
	A	Location	NA	NA
	B	Total area	NA	NA
19	Fire Control Room:			
	A	Fire Detection System panel	NA	NA
	B	Flow switch panel	NA	NA
	C	P A system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plan	NA	NA
20	Special Fire Protection for special risk if any			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter no. F6/DFS/MS/NDZ/2023/4174 dated 07.11.2023 have been rectified.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/NDZ/2018/2088 dated 12.09.2018 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Sumit Kumar
06/08/2025
Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

7/8/25

Dy. C.F.O. (1002)

Div 07/08/25

C.F.O.

14/8/2025

Principal Director

CFO to Secy.

CFO/K

14/08/25

ADO (SPM)

F.T. letter is put up for signature, please.

Sumit Kumar
19/08/2025

C.F.O.

19/8/2025

MS