

2-98

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/School/WZ/2025/ 679

Dated: 22/08/2025

To,

The Incharge/Principal,  
Shri Hanuman Sanskrit Maha Vidyalaya,  
F-487/3, Raghubir Nagar,  
New Delhi-110027.

Sub: Regarding renewal of Fire Safety Certificate in r/o Shri Hanuman Sanskrit Maha Vidyalaya, located at F-487/3, Raghubir Nagar, New Delhi-110027. (School ID:- 1515083)

Sir,

This is in reference to your letter No. HSMV/79/2025 dated 17/07/2025, on the subject cited above. In this connection, it is to inform you that the school building was inspected by the officer concerned of this department on 05/08/2025, in the presence of Sh. Jai Prakash Sharma (H.O.S.) to check the fire safety arrangements provided in the building.

During Inspection, it has been observed that the said school is running at ground + 02 upper floors, was already issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/814 dated 29/07/2022. Fire safety arrangements such as fire extinguisher, etc are provided. **However the following Shortcomings were observed.**

1. First Aid Hose reels are provided but not functional.
2. Terrace level Fire Pump capacity of 450LPM is provided but not functional.
3. Exit Signage's are found removed at some places.


In view of above Shortcomings, **the application for renewal of Fire safety Certificate is not considered at this stage & rejected.** The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,

  
Virendra Singh  
Chief Fire Officer

Copy To: -

1. The Director, Directorate of Education old Secretariat, Delhi-110054.

1/c  
  
24/8/2025