



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



No. F.6/DFS/MS/WZ/GH/2025/ **318**

Dated: **10/07/2025**

To,

Mr. Radha Aggarwal,  
House No.C-8/16,  
Model Town,  
New Delhi-110009.

**Sub:** Renewal of FSC in r/o M/s Shri Om Guest House located at 2036 First Floor, H.C.Sen Road, Chandni Chowk, Delhi-110006.

Sir,

This is refer to online application no. 2025062010349 dated 20.06.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.07.2025**, in presence of **Mr. Ankush (Accountant)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD is not provided in staircases.
2. Fire extinguisher are empty & not functional.
3. First Aid hose reel is provided but not functional.
4. Terrace Fire pump with capacity of 225 LPM found replaced with smaller capacity pump.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt)  
[p://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Copy To:-

1. MCD Portal Id- 2025062010349 dated 20.06.2025.