



C/7

Dated: 04/05/2026

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F.6/DFS/MS/EH/SZ/2026/438

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name of M/s. Shri Radhy Radhy Textiles, located at Concourse Level, in Hauz Khas underground Metro Station Magenta, Line 8, Hauz Khas, New Delhi-110016. Owned/Occupied by M/s. Shri Radhy Radhy Textiles, was inspected by the officer concerned of this department on 27/04/2026 in the presence Sh. Santosh Kumar and found that the said eating house/restaurant premise has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy Class "Assembly" (Group-D) (Restaurant at Concourse Level only) and validity up to 31/03/2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 04/05/2026..... at New Delhi by


(A.K. Malik)
Chief Fire Officer
12 JEF

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. to ensure the occupancy as detailed above & deviation if any.
2. The owner/occupier, M/s. Shri Radhy Radhy Textiles, located at upper ground floor, Hauz Khas Metro Station Magenta, Line 8, Hauz Khas, New Delhi-110016. (Online Portal ID No. - 2026040304189 dated-03/04/2026)
3. Ms. Nabila Mariyam (Sr/DGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building	M/s. Shri Radhy Radhy Textiles; Located at, Hauz Khas underground Metro Station Magenta, Line 8, Hauz Khas, New Delhi-110016.		
2. Type of Occupancy	Group-D Assembly Building, Eating house at Concourse Level.		
3. Type of Case	New Case		
4. Details of Previous NOC	Nil		
5. Fire Safety directives letter No	F.6/DFS/MS/Asscmby/UG/2024/SZ/389 dated-24/06/2024 (Metro Station)		
6. Date of inspection	24/04/2026		
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)		
8. Name and designation of officers From the building side	Sh. Santosh Kumar		
9. Year of Construction	2010 (As per online application)		
10. Applicant's letter No.	Online-ID No - 2026040304189 dated-03/04/2026		

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building	F.6/DFS/MS/Assembly/UG/2024/SZ/389 dated-24/06/2024 (Metro Station)		
	• Road width	NA	13m	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	Abut on Road	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Provided & Maintained by Metro Station		
	• Upper Floors	NA	NA	NA
	• Basements	02 Nos	As above	MR
	b. Width of staircases	Provided & Maintained by Metro Station		
	• Upper Floor	NA	As above	NA
	• Basements	2x2.0m	Provided	MR
	c. Protection of exits	Provided & Maintained by Metro Station		
	• Fire check door	Required	Provided*	MR
	• Pressurization	NA	As above	NA
	d. No. of continuous staircases to terrace	Required	Provided*	MR
	e. Width of Corridor	Required	Provided*	MR
	f. Door Size	2x2m	2.3m, 02m & 02m	MR
3.	Compartmentation	Provided & Maintained by Metro Station		
	a) Fire check door	NA	As above	NA
	b) Sealing of electrical shafts	NA	As above	NA
	c) Fire Rating of shaft door	NA	As above	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	As above	NA
4.	Smoke Management System	Provided & Maintained by Metro Station		
	a) Basements	NA	As above	NA
	b) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	a) Total numbers	06 Nos.	10 Provided.	MR
	b) Types	ABC/CO ₂	ABC-07 & CO ₂ -03	MR

	c) IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels Provided & Maintained by Metro Station			
	a) Total numbers on each floor	01 No near restt.	Provided*	MR
	b) Length of hose reel hose	30mm	Provided*	MR
	c) Nozzle diameter	5m	Provided*	MR
7.	Automatic fire detection and alarming system Provided & Maintained by Metro Station			
	a) Type of detectors	NA	As above	NA
	b) Location of Main Panel	NA	As above	NA
	c) Location of Repeater Panel	NA	As above	NA
	d) Alternate source of power	NA	As above	NA
	e) Hooters' Location	NA	As above	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System Provided & Maintained by Metro Station			
	a) Basement	NA	As above	NA
	b) Ground & Upper Floors	NA	As above	NA
	c) Sprinkler above false ceiling	NA	Provided*	NA
11.	Internal Hydrants Provided & Maintained by Metro Station			
	a) Size of riser/down-comer	150mm.	Provided*	MR
	b) Number of hydrants per floor	01 Nos.	Provided*	MR
	c) Hose Box	01 Nos.	Provided*	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	As above	NA
	b) Hose Box	NA	As above	NA
13.	Pumping Arrangements			
	• Ground Level	Provided & Maintained by Metro Station		
	➤ Discharge of main Pump	NA	2839 LPM	NA
	➤ Head of Main pump	NA	75 m	NA
	➤ Number of main pumps	NA	02	NA
	➤ Jockey Pump out put	NA	2x180 LPM	NA
	➤ Jockey pump head	NA	75 m	NA
	➤ Standby Pump out put	NA	2839 LPM	NA
	➤ Standby Pump Head	NA	75 m	NA
	➤ Auto Starting/Manual Stopping	NA	Provided*	NA
	➤ Pump House Access	NA	Provided*	NA
	Terrace level			
	➤ Discharge of pump	450LPM	As above	MR
	➤ Head of the pump	40m	As above	MR
	➤ Power Supply	Required	Provided*	MR
	➤ Auto Starting of pump	Required	Provided*	MR
14.	Captive Water Storage for firefighting Provided & Maintained by Metro Station			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	Required	Provided*	MR
	➤ Fire service inlet	Required	Provided*	MR
	➤ Access to tank	Required	Provided*	MR

N/22


5.	Exit Signage.			
6.	Provision of Lifts	Required	Provided	MR
	a) Pressurization of Lift Shaft	Provided & Maintained by Metro Station		
	b) Pressurization of Lift lobby	NA	As above	NA
	c) Communication In lift Car	NA	As above	NA
	d) Fireman's Grounding Switch	NA	As above	NA
	e) Lift Signage	NA	As above	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room	Provided & Maintained by Metro Station		
	a) Detector System Panel	NA	As above	NA
	b) Flow Switch Panel	NA	As above	NA
	c) PA System Panel	NA	As above	NA
	d) Battery backup	NA	As above	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Note.* Fire safety arrangements provided & maintained by Hauz Khas Underground Metro Station, Line-8, New Delhi and FSC has been already issued to the said metro station vide letter No. F.6/DFS/MS/Assembly/UG/2024/SZ/389 dated-24/06/2024.

The fire protection systems provided in the building were randomly checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention & fire safety requirement under the rules and it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010. Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal-02/05/2026


 Signature of the Inspecting Officer
 Name - Sarabjeet Singh
 Designation - ADO(BCP)

DO (SD)


 Ravinder Singh


 29/4/26
 A.K. MALIK

Principal Director

Policy is already moved for approval. C/o (SZ)


 A.K. MALIK


 Principal Director