

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hosp/NDZ/2026/204

Dated: 29/05/2026

To,

The Director,
Shri Ram Ossam Multi Specialty & Ortho Hospital 175,
Jagriti Enclave, Bhartendu,
Harish Chandra Marg,
East Delhi - 110092.

Sub: - Reg Fire Safety Certificate in r/o Shri Ram Ossam Multi Specialty & Ortho Hospital 175,
Jagriti Enclave, Bhartendu, Harish Chandra Marg East Delhi - 110092.

Sir,

With reference to your letter via outdoor diary no. 676 Dated 23/04/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officers concerned of this department on dated 18/05/2026 in the presence of Sh. Deepak Aggarwal, Owner to see the compliance of and observed though most of the shortcomings following. The premises is comprised of basement, stilt, ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. Sealing of electrical shafts not provided.
2. Smoke management system in basement is not provided.
3. Exit signages are not provided.
4. Communication in lift car not provided.
5. Lift signage is not provided.
6. Pressurization of lift lobby not provided in basement.

In view of above, Fire Safety Certificate **cannot be considered** at this stage. You are requested to apply for fire safety certificate after rectification of above-mentioned shortcomings under intimation to this department.

Yours faithfully,


22/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service