



C/19



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2025/NDZ/244

Dated 17/04/2025

To,

The Principal,
Shri Ram Momorial Public School,
D-Block, St. No.13, Ashok Nagar,
Wazirabad Road, Delhi-110093

Sub:- Regarding Issuance of Fire Safety Certificate r/o Shri Ram Momorial Public School, D-Block,
St. No.13, Ashok Nagar, Wazirabad Road, Delhi-110093.

Sir,

With reference to your letter no. nil dated 15/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 07/04/2025 of the above mentioned School from fire safety point of view in presence of the Mrs. Shashi Principal of the school. The building comprised of Ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. First Aid Hose reels provided but not functional.
2. Terrace pump 4500 lpm provided but not functional.
3. An overhead tank capacity 8,000 liters provided against the requirement of 10,000 liters.
4. Exit Signage found removed.
- 5.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar, Delhi-110053