

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/1339

Dated: 21 / 11 / 2025

FIRE SAFETY CERTIFICATE

Certified that the building of Shri S.D. Co-Ed. Sec. School, Sadar Bazar, Delhi Cantt. New Delhi - 110010, comprised of ground plus one upper floor only, was issued Fire Safety Certificate vide this department letter No.F.6/DFS/MS/School/2022/SZ/1139 dated 12.10.2022. The premise was re-inspected by the officer concerned of this department on 03/11/2025 in the presence of Smt Pushpa Rani (Vice-Principal) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance Director of Education Circular No. 3298 to 3398 dated 01/03/2011, D.O.E Circular 262-232 dated 17/01/2005 and that the said premises/building is fit for occupancy class "**Educational Group B**" with effect from 21 / 11 / 2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21 / 11 / 2025 at New Delhi by


(A.K. Malik)

Dy. Chief Fire Officer



Copy to: -

1. Smt Pushpa Rani (Vice-Principal), Shri S.D. Co-Ed. Sec. School, Sadar Bazar, Delhi Cantt. Delhi -10
2. The Director of Education, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002

Condition for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in

N/7

INSPECTION REPORT

1.	Name & address of the building	Shri S.D. Co-Ed. Sec. School, Sadar Bazar, Delhi Cantt. New Delhi - 110010		
2.	Type of Occupancy	Educational (Group B)		
3.	Building Comprised of	Ground + First floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2022/SZ/1139 dated 12.10.2022		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	03/11/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Pushpa Rani (Vice Principal)		
10.	Year of Construction	2018		
11.	Applicant's letter No.	Nil Outdoor Diary No. 5768 dated 10/09/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	4.50 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 No	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.5m & 1.25m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01	Provided	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.00 mtr	Provided	MR

3.	Compartmentation			
	•	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 APHC	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	Required	08 nos.	MR
	• Types	ABC / CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box			

✓

13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19.	Fire Control Room			
	> Detector system panel	N/A	N/A	N/A
	> Flow Switch Panel	N/A	N/A	N/A
	> PA System Panel	N/A	N/A	N/A
	> Battery backup	N/A	N/A	N/A
	> Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	ABC type fire extinguisher provided near electric panel	M/R



The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/1139 dated 12.10.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


Accordingly, DFA is put up for perusal/approval & signature please.



 Signature of the Inspecting Officer
 Name: Kaushal Kishore
 Designation: ADO (SJ)

DO (SJ)



 10/11/25
 A.K. MALIK


 Principal

my. CF + S

 10/11/25


 12/11/25
 A.K. MALIK

my. CF (SZ)

 12/11/25
 Ravinder Singh

DO (SD)