



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 477

Dated: 15/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Shri S.S.D. Jain Girls Middle School located at 4106, Gali Jain Temple, Aryapura, Sabzi Mandi, Delhi-110007 comprised of ground & 02 upper floors, but (school is running at first & second floor only) owned/occupied by Shri S.S.D. Jain Girls Middle School was granted FSC by this department vide letter F6/DFS/MS/School/2022/WZ/353 Dated: 31.03.2022. The premises was re-inspected by the officer concerned of this department on 02.04.2025 in presence of Smt. Kamlesh kumar (Head Mistress) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy class "Group B Educational (School) for first floor & second floor only" with effect from 15/04/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 15/04/2025 at New Delhi by

(Atul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi – 110054.
2. The Incharge, Shri S.S.D. Jain Girls Middle School located at 4106, Gali Jain Temple, Aryapura, Sabzi Mandi, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
8. The Fire Safety Certificate is valid only for first & second floor. In case of any violation, this FSC will be treated as null & void.

INSPECTION REPORT

1. Name & address of the building : Shri S.S.D. Jain Girls Middle School, Aryapura, Sabzi Mandi, Delhi-110007.
2. Composition of Building : Ground & 02 upper floors, (school is running on first & second floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/WZ/353 Dated: 31.03.2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 02.04.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Smt. Kamlesh kumar (Head Mistress)
10. Year of Construction : 1955-56
11. Applicant's letter No. : Letter No. SSD/GMS/Fire Safety File/2025 dated: 20.03.2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O. E Circular dated 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	35cm & 30cm	MR (Being old building)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	40cm	MR (Being old building)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	03nos	04nos	MR
	• Types	ABC/CO2	ABC-04	MR
	• ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.		01	Provided	MR
	<ul style="list-style-type: none">• Total numbers on each floor• Length of hose reel hose• Nozzle diameter		30m	Provided	MR
			5mm	Provided	MR
7	Automatic fire detection and alarming system.		NA	NA	NA
	<ul style="list-style-type: none">• Type of detectors• Location of Main Panel• Location of Repeater Panel• Alternate source of power• Hooters' Location		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
8	MOEFA		NA	NA	NA
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none">• Basement• Upper Floor• Sprinkler above false ceiling		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
11	Internal Hydrants				
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
12	Yard Hydrants.				
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box		NA	NA	NA
			NA	NA	NA
13	Pumping Arrangements.				
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access		N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			NA	NA	NA
			NA	NA	NA
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
	Terrace level <ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump		450 LPM	Provided	MR
			40m	Provided	MR
			Required	Provided	MR
			Required	Provided	MR
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none">• Underground tank capacity<ul style="list-style-type: none">➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity		NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			NA	NA	NA
			5000ltr	5000ltr	MR
15	Exit Signage.		Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 17.01.2005, the FSC issued vide letter of even no. F6/DFS/MS/School/2022/WZ/353 Dated: 31.03.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

CFO/ 1180 MW
Dated: 7/4/2025

by 07/04/2025

CFO/ 8/4/2025
Director

Handwritten signature

conf... P.T.O.