



C/28



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/NDZ/GH/2025/ 220

Dated: 08/05/2025

To,

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Shri Vinayak Guest House
Located at 7813-14 & 7840, Saran Building, Ram Nagar, Main Qutab Road, Pahar Ganj,
New Delhi-110055.**

Sir,

This has reference to MCD application ID No. 2025040905992 dated 09/04/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Mr. Nitin Goel dated 02/05/2025. The building comprised of ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. First Aid Hose reels are provided but not functional.
2. Terrace pump 450 lpm provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE