

C/88



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/CGHS/2025/SZ/ 197

Dated: 29/04/2025

To

Sh. Vinod Kumar Gahlot,
 President, Shriniketan CGHS Ltd,
 Plot No. 01, Sector-07,
 Dwarka, New Delhi-110075

Sub: Renewal of Fire Safety Certificate in r/o "Shriniketan CGHS Ltd" situated at Plot No. 01, Sector-07, Dwarka, New Delhi-110075

Sir,

Please refer to your letter No. Nil dated 05/04/2025 received through outdoor diary No. 582 dated 15/04/2025, on the subject cited above. In this connection, the said residential complex was visited by the officer concerned of this department on 23/04/2025 in the presence of Sh. Sanjay Malhotra (Secretary) to verify the compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/CGHS/2025/SZ/24 dated 13/01/2025 and the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present Status
1.	Six-meter-wide internal road around the building found encroached.	Not Complied
2.	The trimming of trees is required for free movement of fire vehicle in case of fire emergency.	Partially Complied
3.	Hose Reels & Hydrant system found non-functional.	Complied
4.	All the pumps at ground level found non-functional.	Complied
5.	Exit signage's & lift signage's found removed.	Complied

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are advised to rectify the left-over shortcomings under intimation to this department for further action.

Yours faithfully,

(ATUL GARG)
 DIRECTOR

Ph. 011-23414000

01/08/25