



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/CGHS/2025/SZ/24

Dated: 13/01/2025

To

The President,  
Sri Niketan CGHS Ltd.  
Plot No. 01, Sector-7,  
Dwarka, New Delhi-110075

**Sub: Renewal of Fire safety Certificate in r/o Shriniketan CGHS Ltd. located at Plot No. 01, Sector-7, Dwarka, New Delhi-110075**

Sir,

Please refer to your letter received through outdoor diary No. 10336 dated 13/12/2024, on the subject cited above. In this connection, it is to inform to you that the said premises was inspected by the officer concerned of this department on 03/01/2025 in the presence of Sh. Vinod Kumar Gahlot from fire safety & means of escape point of view. During course of inspection, the shortcoming observed are as below;

1. Six-meter-wide internal road around the building found encroached.
2. The trimming of trees is required for free movement of fire vehicle in case of fire emergency.
3. Hose Reels & Hydrants system found non-functional.
4. All the Pumps at ground level found nonfunctional.
5. Exit signage's & lift signage's found removed.

In view of the above shortcomings, renewal of Fire Safety Certificate is rejected. You are advised to rectify the above-mentioned shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate shall be at own risk and responsibility of the management committee.

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Joint Director (Bldg), Delhi Development Authority, Vikas Sadan, INA, New Delhi-110023