

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/GH/SZ/350

Dated: 14./08/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Shyam Guest House located at 4234, Tel Mandi, Pahar Ganj, New Delhi.

Sir,

This has reference to **MCD Portal ID No. 2025071411362 dated 14/07/2025** on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 24/07/2025 in the presence of Md. Amir, Manager and to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-


1. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
2. Guest house was also found running at 4th & 5th floor through owner has submitted an affidavit dated 05/12/2019 not to use any floor above 3rd floor. Closure/sealing of the same shall be ensured by the local authority /licensing authority.

The above observations has already been issued and communicated earlier by this department vide letter of even no 751 dated 31/12/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Encl: as above.

Yours faithfully,


13/8/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

