

C/111

 **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**



No. F.6/DFS/MS/GH/SZ/2026/ 81

Dated: 23/01/2026

To,

Sh. Mohit Dhama,  
M/s Signature Plaza (Unit of MP Brothers),  
B-11, 1<sup>st</sup> & 2<sup>nd</sup> Floor, East of Kailash,  
New Delhi-110065

**Subject: - Application for renewal of Fire Safety Certificate in r/o M/s Signature Plaza (Unit of MP Brothers), B-11, 1<sup>st</sup> & 2<sup>nd</sup> Floor, East of Kailash, New Delhi-110065.**


Sir,

This has reference to MCD application ID No. 2025122316024 dated 26/12/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 10/01/2026 in presence of Sh. Mohit Dhama. The premises is comprised of Basement, Ground plus 03 upper floors but guest house is running first floor & second floor only (3<sup>rd</sup> floor owner residence). **The following shortcomings were observed during the time of inspection.**

1. First-aid-Hose Reels provided but not functional at the time of inspection.
2. MOEFA is provided but not functional.
3. Over head pump capacity 900 lpm head 40 meters found removed.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
23/01/26  
(A. K. MALIK)  
DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
b/c Q.

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi  
MCD ID No. 2025120515442