

c/97

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F.6/DFS/MS/GH/NDZ/2025 / 57

Dated 31/01/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub:- Inspection report in respect of M/s. Silver Palace Located at 614, Mantola, Paharganj, New Delhi- 110055.

Sir,

Please refer to your Online Application ID. No. 2025010200070 dated-02/01/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 24/01/2025 in the presence of Sh. Khem Pal Singh to check the Fire safety arrangements.

During inspection, it was observed that the Guest house is running at Ground + 03 upper floor, total 27 guest rooms, Ground floor (reception + 06 guest rooms & store room, 1st floor to 3rd floor (07 guest rooms at each floor) and 4th floor and not in use as per affidavit dated 18/03/2020, in a building comprised of Ground + 04 Upper Floors. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Pumping Arrangement & Exit Signage etc, are provided. However, following shortcomings were observed:-

1. First-Aid hose reel are provided but not functional.
2. MOEFA is provided but not functional.
3. Public Address System is provided but not functional.
4. Terrace pump of capacity of 225 is provided but not functional.
5. Exit signage's are found removed at some places.

In view of above shortcomings, the application for renewal fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier M/s. Silver Palace, 614, Mantola, Paharganj, New Delhi- 110055.
2. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.