

C/1163

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001.**

No.F.6/DFS/MS/Hosp /2025/1090

Dated: 19/06/2025

To,
The Chief Security Officer,
Sir Ganga Ram Hospital,
Rajinder Nagar, New Delhi.

Sub: Regarding issuance of FSC in r/o Sir Ganga Ram Hospital, Rajinder Nagar, New Delhi.

Sir,
This has reference to letter no. SGRH/FIRE/SGRF/NOC/09/2025 dated 10.05.2025, on the subject cited above. In this connection it is to inform you that the site was visited by the officers concerned of this department on **13/06/2025** in the presence of Sh. Kuldeep Lohani, CSO & Dr. D.S Badole and observed that the shortcomings issued earlier vide letter no. F6/DFS/MS/2025/109 dated 13.03.2025 (copy enclosed), have not been complied in toto.

Therefore, you are requested to submit the point wise compliance of the aforesaid letter for further consideration in the matter.

Yours faithfully,

Encl. As Above.

(Atul Garg)
DIRECTOR
Delhi Fire Service
F/6

Copy to:

1. The Commissioner, MCD, Civic Center, New Delhi.
2. The Director Administration, Sir Ganga Ram, Hospital, Rajinder Nagar, New Delhi-60.
3. The Director General of Health Services, F-17, Arjun Gali Karkardooma, Anand Vihar, New Delhi.

C-153

c/1162

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2025/109

Dated 13/03/2025

To,

Sh. Kuldeep Lohani,
Chief Security Officer.
Sir Ganga Ram Hospital,
New Delhi - 110060.

Sub: Regarding renewal of Fire Safety Certificate for Sir Ganga Ram Hospital Complex, at Rajinder Nagar, New Delhi - 110060.

Sir,

This has a reference to your mail id kuldeep.lohani@sgrh.com dated 06.02.2025, on the subject cited above. In this regard, this is to inform you that the site was inspected by officers concerned of this department on 06/03/2025 in the presence of Sh. Kuldeep Lohani (CSO) & Dr. D.S. Badole and following shortcomings were observed: -

1. Fire check door provided for connection to E block for compartmentation found removed at 4th floor and door closers also found removed from some fire check doors.
2. Lift lobby pressurization found removed at some lifts.
3. Detectors are not provided at some offices required to be extended to left out area.
4. Sprinklers at 5th floor of old building is not provided, required to be extended at 5th floor also.
5. Basement is being used for office which is not allowed as per sanctioned plan.
6. Hose reel and hydrant is not provided at basement required to be extended to basement left out area.
7. Corridor and lift lobby found encroached by making it waiting room and storing of other items, required to be removed.
8. Lift signage not provided at some places.
9. Trimming of tree is required to free movement of fire vehicle.
10. At few floors, repairs of AHU and renovation work is being carried out.

In view of above, the case is rejected and fire safety certificate (FSC) cannot be renewed at this stage. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
01123414000

Copy to:-

1. The Commissioner, MCD, Civic Center, New Delhi.
2. The Director General of Health Services, F-17, Arjun Gali Karkardoom, Anand Vihar New Delhi.
3. The Director Administration, Sir Ganga Ram, Hospital, Rajinder Nagar, New Delhi-110060.