



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 763

Dated: 10/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Sister Nivedita Sarvodaya Kanya Vidyalaya**, A-Block, Defence Colony, New Delhi-110049 (School ID:1924025), comprised of Ground + 03 upper floors, owned/occupied by Directorate of Education, Govt. of NCT of Delhi, was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/2022/SZ/2022/11 dated 05/01/2022. The school premise was re-inspected by the officer concerned of this department on dated 26/05/2025 in the presence of Sh. Sumit (Principal) and found that said premises/building is fit for occupancy class "**Educational Group B**" (School) with effect from 10/06/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/06/2025 at New Delhi by

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Principal, Sister Nivedita Sarvodaya Kanya Vidyalaya, A-Block, Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate:**

1. The stairs/passagage shall be kept clear from any obstruction & free from lock & key, as seen during the inspection otherwise the FSC shall be null & void.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N-27

INSPECTION REPORT				
1.	Name & address of the building	Sister Nivedita Sarvodaya Kanya Vidyalaya (A-Block), New Building, Defence Colony, New Delhi-110024 (ID: 1924025)		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground + 3 Upper Floor		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2022/SZ/11 Dt. 05/01/2022		
6.	Fire Safety directives Letter No.	Nil		
7.	Date of inspection	26/05/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Sumit (Principal)		
10.	Year of Construction	1982		
11.	Applicant's letter No.	SNSKV/785 dated 05/05/2025 received through outdoor diary No. 1286 dated 05/05/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			MR
	• Road width	6m	12m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			MR
	• Upper floors	2 Nos	3 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			MR
	• Upper floors	1.50 mtr	1.80 mtr x 3	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	Three	MR
	e. Width of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1.0 mtr	1.10m x 2	MR
3.	Compartmentation			N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			N/A
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			MR
	• Total numbers	10 Nos	20 Nos	MR
	• Types	ABC/W.CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			MR
	• Total numbers on each floor	2 Nos	4 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

hr

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• <b>Ground Level</b>			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• <b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

*[Signature]*


N-19

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for protection of special risks, if any;			N/A


The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/11 dated 05/01/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

  
Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)


DO (SD)  30/6/25

CFD/MS  3/6/2025

DO (SD)  4/6/25

ADO (SJ)

Sir, F.T letter is put up for your ding pl

CFD/MS  9/6/2025

  
6/6/25

MS cell