


No.F6/DFS/MS/School/SZ/2025/532

Dated: 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sita Ram Public School located at Madanpur Khadar, New Delhi-76**, was granted Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/2006/1913 dated 04.08.2006 for Ground + 02 upper floors. The School building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 21.04.2025 in the presence of Mr. Anang Pal (Manager) and found that the school is running at Ground + 02 upper floors of the building is comprised Ground + 03 upper floors (3rd floor being used as storage purpose only as per the affidavit submitted by the school management). The building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 262-362 dated-17/01/2005 issued by the Directorate of Education and the building (up to **Ground + 02 upper floors**) is fit for occupancy of Group B" **Educational Building**" (School) with effect from 24/04/2025 renewed for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....24/04/2025..at New Delhi by


(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, 9th floor, Shyama Prashad Mukherjee Civic Centre : to ensure the occupancy as per the FSC.
2. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
3. The Principal, Sita Ram Public School located at Madanpur Khadar, New Delhi-76.

Conditions for the validity of Fire Safety Certificate

1. **This Fire Safety Certificate is valid for Ground + 02 upper floors only.**
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sita Ram Public School located at Madanpur Khadar, New Delhi-76.		
2	Building is comprised of	Ground + 03 upper floors (School running at Ground + 02 upper floor & 3 rd floor shall be used for storage purpose only as per the undertaking submitted by the owner)		
3	Type of occupancy	Education, Group-B		
4	Type of case	Renewal- Addition/ Alteration (addition of 3 rd floor on existing building)		
5	Details of previous FSC	F.6/DFS/MS/2006/1913 dated 04.08.2006		
6	Fire safety direction letter no.	DOE Circular 262-362 dated-17/01/2005		
7	Date of inspection	21.04.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Anang Pal (Manager)		
10	Year of construction	2006 & 2018		
11	Applicant's letter no.	Outdoor diary no.		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	Required	2.0 m	MR (two lengths hose distance from road)
	B Gate width	NA	NA	NA
	C Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos.	2 nos.	MR
	b Basement	NA	NA	NA
	B Width of staircases			
	a Upper floor	2 nos. (Exits)	GF to SF-1.5 m (Iron) GF to TF- 1.20 m	MR
	b Basement	NA	NA	NA
	C Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	NA	NA	NA
	F Door size	1.0 mtrs.	1.0 mtrs. (class room)	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basement	NA	NA	NA
	B Upper floor	NA	NA	NA
5.	Fire Extinguisher:			
	A Total numbers	08 nos.	08 nos.	MR
	B Types	CO ₂ & ABC	Provided	MR
	C ISI marking	Required	Provided	MR
6	First-Aid-Hose Reel:			
	A Total numbers of each floor	01 no.	01 no.	MR
	B Length of hose reel hose	30 m	30 m	MR
	C Nozzle diameter	5 mm	5 mm	MR

7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	NA	NA
	B	Location of main panel	NA	NA
	C	Location of repeater panel	NA	NA
	D	Alternate source of power	NA	NA
	E	Hooters	NA	NA
8	MOEFA:		NA	NA
9	Public Address System:		NA	NA
10	Automatic Sprinkler System:			
	A	Basement	NA	NA
	B	Upper floor	NA	NA
	C	Sprinkler above false ceiling	NA	NA
11	Internal Hydrants:			
	A	Size of riser/down-comer	NA	NA
	B	Number of hydrants per floor	NA	NA
	C	Hose box	NA	NA
12	Yard Hydrants:			
	A	Total number of hydrants	NA	NA
	B	Hose box	NA	NA
13	Pumping Arrangements:			
	A Ground level			
	a	Discharge of main pump	NA	NA
	b	Head of main pump	NA	NA
	c	Number of main pumps	NA	NA
	d	Jockey pump out put	NA	NA
	e	Jockey pump head	NA	NA
	f	Standby pump out put	NA	NA
	g	Standby pump head	NA	NA
	h	Auto starting /manual stopping	NA	NA
	i	Pump house access	NA	NA
	B Terrace Level			
	a	Discharge of pump	450 LPM	Provided
	b	Head of the pump	40 mtrs	MR
	c	Power supply	Required	MR
	d	Auto starting of pump	Required	MR
14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	10000 ltrs	NA
15	Exit Signage:		Required	Provided
16	Provision of Lifts:		Required	MR
	A	Pressurization of lift shaft	NA	MR
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		NA	NA
18	Refuge Area:		NA	NA
	A	Total area	NA	NA
	B	Location	NA	NA
			NA	NA
			NA	NA

19 Fire Control Room:				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Note: The FSC to this school had been issued for Ground + 02 upper floors vide letter no. F.6/DFS/MS/2006/1913 dated 04.08.2006 without accessibility but within reach of two lengths of hose. The school management has added 3rd floor to the building and has submitted an undertaking that same shall be used for storage purposes only and teaching activity shall be limited to 2nd floor only.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

If agreed to the note above, & In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education circular 262-362 dated-17/01/2005, the FSC issued vide letter no. F.6/DFS/MS/2006/1913 dated 04.08.2006 is recommended to be renewed upto 2nd floor only.

Signature of the Inspecting Officer
Name: Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD) *[Signature]* 22/4/25

CRD (MS) *[Signature]* 23/4/2025

Director *[Signature]* 24/4/25

[Signature]