



C 145



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/WZ/School/2025/ 1179

Dated : 23/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the S.J.K Public School, located at A-204,205, Raghbir Nagar, New Delhi- 110027, comprised of ground + three upper floors only. Owned/ occupied by S.J.K. Public School has already issued FSC by this department vide letter No. F.6/DFS/MS/WZ/School/2022/911 dated 18/08/2022. The premises was re-inspected by officer concern of this department on 12/09/2025 in the presence of M/s. Gurcharan kaur and observed that all the fire prevention and fire safety arrangements provide in the premises found in good working condition. The premises have deemed complied with Director of Education Circular dated 01/03/2011/NBC (Part-IV) and that the building/premises is fit for occupancy class "Educational" Group-B, with effect from 31/03/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 conditions mentioned below.

Issued on 23/09/2025 at New Delhi by

  
23/09/2025  
Virendra Singh  
Chief Fire Officer

Copy to: -

1. The Principal, S.J.K Public School, located at A-204,205, Raghbir Nagar, New Delhi- 110027.
2. The Director, Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

# INSPECTION REPORT

122

1.	Name & address of the building	S.J.K Public School Located at A-204,205, Raghubir Nagar, New Delhi-110027.
2.	Type of Occupancy	Educational (Ground + 03 Upper Floors)
3.	Type of Case	Renewal
4.	Details of previous NOC	F.6/DFS/MS/WZ/School/2022/911 dated 18/08/2022
5.	Fire Safety directives letter No	DOE 3298-3398 dated 01/03/2011/NBC (Part-IV)
6.	Date of inspection	11/09/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	M/s Gureharan kaur
9.	Year of Construction	2005 (As per prev. insp. report dtd.-02/08/2022)
10.	Applicant's letter No.	Email dated 25/08/2025

The said School building is running at (ground and three upper floors), was issued FSC vide letter No.F.6/DFS/MS/WZ/School/2022/911 dated 18/08/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	06 m	06 Provided	MR
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	4.5 m	On Road	MR
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	02	02 Provided	MR
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	1.5 m	1X1.5 m & 1X 0.70 m	MR (Old case)
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR(Old case)
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	08 nos.	Provided	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	CO <sub>2</sub> , ABC type	ABC & CO <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	Required	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr.	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Note: - General requirement for schools as per Director of education circular dated 01/03/2011.

1. Escape route ..... Clear
2. LPG cylinders in laboratories ..... Nil
3. Electric wiring ... Conduit Wiring ..... MCB and ELCB ..... Electric circuit .....
4. Electric meter board ..... Not under the staircase .....
5. Basement use as per BBL 1983 ..... NA .....
6. Emergency telephone no. board ..... Displayed .....
7. Generator set ..... Nil .....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F.6/DFS/MS/WZ/School/2022/911 dated 18/08/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: Assistant Divisional Officer

327/AD0/mn

15/09/25

DCFO/8/8-WD

Dated 17/09/25

CFD

18/09/2025

Principal Director

ADD (mn)

CFD

19/09/2025