




No.F6/DFS/MS/School/SZ/2025/ 1107

Dated: 08/09/25

FIRE SAFETY CERTIFICATE

Certified that the S.K. Payal Public School located at Kasana Colony, Mohan Baba Nagar, New Delhi-44, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1712 dated 30.11.2017 for Ground + 01 upper floor in the building of Basement + Ground + 02 upper floors. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 25.08.2025 in the presence of Mrs. Chitra Kasana (Principal) and found that the school running at Ground + 02 upper floors of the building which comprised of Basement (Closed) + Ground + 02 upper floors. The school building has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 262-232 dated-17/01/2005 issued by the Directorate of Education and the school (Ground + 02 upper floors) is fit for occupancy of Group B "Educational Building" with effect from 08/09/25 renewed for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 08/09/25 at New Delhi by

  
6/9/2025  
(Virendra Singh)  
Chief Fire Officer  
% 11

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, S.K. Payal Public School located at Kasana Colony, Mohan Baba Nagar, New Delhi-44.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for Ground + 02 upper floors only.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.
9. Basement shall remain closed till an additional/alternate staircase is provided.

## INSPECTION REPORT

1	Name & address of the building	S.K. Payal Public School located at Kasana Colony, Mohan Baba Nagar, New Delhi-44.		
2	Building is comprised of	Basement (Closed) + Ground + 02 upper floors		
3	Type of occupancy	Group B- Educational building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2017/SZ/1712 dated 30.11.2017		
6	Fire safety direction letter no.	D.O.E Circular 262-362 dated-17/01/2005		
7	Date of inspection	25.08.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mrs. Chitra Kasana (Principal)		
10	Year of construction	2006		
11	Applicant's letter no.	Outdoor diary no. 5007 dated 19.08.2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	Required	Accessible	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	2 nos.	2 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	Required	1.25 m & 1.16 m	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	1 no.	1 no.	MR
E	Width of corridor	Required	Provided	MR
F	Door size	1.0 m	1.0 m (class room)	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
5.	<b>Fire Extinguisher:</b>			
A	Total numbers	04 nos.	06 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Mark	Provided	MR
6	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR

7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
A	Ground level				
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
B	Terrace Level				
	a)	Discharge of pump	220 LPM	220 LPM	MR
	b)	Head of the pump	Required	Provided	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	2,500 ltrs	3,000 ltrs	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		NA	NA	NA
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA

S.K. Payal Public School located at Kasana Colony, Mohan Baba Nagar, Gurgaon, Haryana

<b>19</b>	<b>Fire Control Room:</b>			
	<b>A</b>	Detector system panel	NA	NA
	<b>B</b>	Flow switch panel	NA	NA
	<b>C</b>	PA system panel	NA	NA
	<b>D</b>	Battery backup	NA	NA
	<b>E</b>	Building floor plans	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular 262-232 Dated-17/01/2005, the FSC issued vide letter no. F6/DFS/MS/School/2017/SZ/1712 dated 30.11.2017 is recommended to be renewed.

*[Signature]*  
25/10/25  
Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SD) *[Signature]*  
26/10/25

CFO *[Signature]*  
2/11/2025

Principal Director  
*[Signature]*

CFO + Issue  
*[Signature]*  
02/10/25

CFO *[Signature]*

ADO (M.R.)

FI is put up

CFO *[Signature]*  
04/11/25  
6/11/2025

MS