



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F6/DFS/MS/WZ/2026/ 156

Dated: 28/04/2026

To,

The Medical Superintendent,
Sonia Hospital Pvt. Ltd.,
1, Gulshan Park, Main Rohtak Road,
Nangloi, Delhi – 110041

Sub: - Surprise inspection report in r/o M/s Sonia Hospital Pvt. Ltd. located at 1, Gulshan Park,
Main Rohtak Road, Nangloi, Delhi – 110041.

Sir,

As per directions of the Competent Authority vide office order no. F6/DFS/HQ/2026/494 dated 20/03/2026, it is to inform you that the surprise inspection of above said Hospital building has been carried out by the officer concerned on 20.04.2026 to verify the compliance of the requisite fire safety measures installed in the building, Mr. Naveen Sharma was present at the time of inspection. During the visit of the following observation were noticed:-

1. Shaft doors are not fire rated at some places.
2. Detectors found removed at some places.
3. Exit Signage found removed at some places.
4. Pressurization of lift lobby found removed.

You are advised to rectify the above-mentioned shortcoming under intimation to this department, till than the occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully

S.K. Dua

Chief Fire Officer
Delhi Fire Service