

C-60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2025/ 168

Dated: 24/ 03 /2025

To

The Vice Principal,
SKV Pataudi House,
Darya Ganj, New Delhi - 110002.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o SKV Pataudi House, Darya Ganj, New Delhi - 110002.

Sir,

This has reference to letter outdoor diary no. 14061 dated 03.03.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 15.03.2025 in the presence of Ms. Babita Singh (Vice Principal) and observed that the building is comprised of ground + 03 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2021/527 dated 29.09.2021 except following which still exists.

1. The school building is not accessible to fire engine as approach road width is less than 06 mtrs.

In view of the above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.