



c-52

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2025/SZ/172

Dated: 22/04/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Sky Rozo situated at B-1/625, 3rd floor, Najafgarh Road, Janakpuri, New Delhi-110058

Sir,

Please refer to online (etl.mcdonline.nic.in) Id. 2025040205315 dated 02/04/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 11/04/2025 in the presence of Sh. Rajat Chopra (Partner) of the eating house and the shortcomings observed are as below.

1. First aid hose-reel provided but non-functional/nozzle missing.
2. Internal hydrant found non-functional & hose box empty.
3. Standby diesel driven fire pump found non-functional & terrace pump removed.
4. The exit signage found removed at some locations.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Sh. Rohit Arora, M/s Sky Rozo situated at B-1/625, 3rd Floor, Najafgarh Road, Janakpuri, New Delhi-110058