



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/School/ 911

Dated: 15/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Skyland Public School, E-9, Vijay Vihar, Ph-II, Rohini, Delhi-85, comprised of Ground + 03 upper floors (but School running at Ground + 02 upper floors) has already been issued FSC by this department vide letter No. F.6/DFS/MS/2022/WZ/School/512 dated 12.05.2022. The premises was re-inspected by the officer concerned of this department on 01.07.2025 in the presence of Sh. Gagan Bindal (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Educational "Group B" with effect from 15/07/2025 for ground + 02 upper floor only a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/07/2025 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Skyland Public School, E-9, Vijay Vihar, Ph-II, Rohini, Delhi-85.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/20

INSPECTION REPORT

1. Name & address of the building : Skyland Public School, E-9, Vijay Vihar, Ph-II, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Comprised of building : Ground + 03 upper floors
4. Type of Case : Renewal (School running at G+2 upper floor only)
5. Details of Previous NOC : F.6/DFS/MS/2022/WZ/School/512 dated 12.05.2022
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 01.07.2025
8. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
9. Name and designation of officers
From the building side : Sh. Gagan Bindal (Manager)
10. Year of Construction : 2000
11. Applicant's letter No. : Online e-mail dated 21.05.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.25m & 1.02m	MR (old case)
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	1.5m	2.0m	MR
	f. Door Size	1m	1.05m	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	07nos.	Provided	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA-	-NA-	-NA-
12.	Yard Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
		10,000ltr	10,000ltr	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel 	-NA-	-NA-	-NA-

N/23

20.	<ul style="list-style-type: none"> PA System Panel Battery backup Building Floor Plans 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/WZ/School/512 dated 12.05.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

DO (NW)
 Dy. CFO(WZ)

08/07/2023

8/7/2023

DCFOI... 265... N/23
 Dated... 8/7/2023

cfo/

41/7/2023

Director

Fi letter to put up to kind perusal and
 Signature please.

Director
 ru

11/7/23