



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/School/WZ/2025/ 1078

Dated: 29/08/2025

FIRE SAFETY CERTIFICATE

Certified that the S. M. Public School, Z-183, Prem Nagar, Nangloi, Delhi-86, comprised of interconnected 02 blocks, B+G+2 & G+2 upper floors and school running in interconnected 02 blocks of, Ground + 02 upper floors was inspected by the officer concerned of this department on 30.07.2025 in the presence of Mr. Joginder Singh (Manager) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy Group B Educational for interconnected 02 blocks of, Ground + 02 upper floors with effect from 29/08/2025 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/08/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, S. M. Public School, Z-183, Prem Nagar, Nangloi, Delhi-86.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule/s/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : S. M. Public School, Z-183, Prem Nagar, Nangloi, Delhi-86.
2. Type of Occupancy : Educational
3. Comprised of building : 02 blocks interconnected B+G+2 & G+2 upper floors
4. Type of Case : New Case (02 blocks interconnected G+2 upper floors)
Basement sealed by brick wall school management given by undertaking not use for basement
5. Details of Previous NOC : F.6/DFS/MS/School/2019/1789 dated 18.09.2022 previous NOC Gr. + 02 upper floors
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 30.07.2025.
8. Name of Inspecting Officer : A. K. Sharma, ADO (Rohini) & D.B Mukherjee, DO (NW)
9. Name and designation of officers
From the building side : Mr. Joginder Singh (Manager)
10. Year of Construction : 2016, 2017 & 2025
11. Applicant's letter No. : Online e-mail dated 26.06.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	03nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.90m, 1.65 & 0.95m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	03nos.	MR
	e. Width of Corridor	1.5m	1.5m to 2.05m	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	13nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

Chy

20.

<div> <div> <div>NA</div> <div>NA</div> <div>NA</div> </div> <div>20.</div> </div>	<ul style="list-style-type: none"> Battery backup Building Floor Plans 	-NA-	-NA-	-NA-
	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 293 dated 25.04.2025, under the rules it is **recommended to grant Fire Safety Certificate** under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Office
Name: - D.B Mukherjee
Designation:- DO/NW

Signature of the Inspecting Officer
Name: - Ajay Kumar Sharma
Designation:- ADO/Rohini

ICFO/379-A/10...

Dated.....7/8/2025

By cfo (nw)

7/8/2025

CFO /
16/01/2025

Principal Director

CFO to Sec.

ADO (Rohini) 19/08/25

FT letter is put up for kind perusal and signature please.

CFO

FT letter is put up for kind perusal and signature please.

CFO / 27/01/2025 MS