



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2025/NDZ/ 278

Dated: 25/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that S. M. International School located at A-133 Main Kaushal Puri Road, Chauhan Patti, Delhi-110094 comprised of ground plus two upper floors only, owned/occupied by S.M. International School was issued FSC vide letter No. F.6/DFS/MS/2017/1870 dated 27/12/2017 for ground floor only. The premises was re-inspected by the officer concerned of this department on dated 17/03/2025 in the presence of Mr. Tarun Sharma (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 25/03/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on.....25/03/2025.....at New Delhi by

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

To:-

The Manger,  
S. M. International School,  
A-133 Main Kaushal Puri Road, Chauhan Patti, Delhi-110094.

Copy to:-

The Dy. Director of Education  
B-Block Yamuna Vihar, Delhi-110053

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

- 2/5
1. Name & address of the building : S.M. International School  
A-133, Main Kaushal Puri Road, Chauhan Patti,  
Delh-110094
  2. Building is comprised of : Ground plus two upper floors only
  3. Type of Occupancy : Educational
  4. Type of Case : Addition/Alteration
  5. Details of Previous NOC letter : F.6/DFS/MS/2017/1870 dated 27/12/2017 (G floor)
  6. Fire Safety direction letter No : NBC Part IV
  7. Date of Inspection : 17/03/2025
  8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
  9. Name and designation of Officer  
from the building side : Mr. Tarun Sharma (Manager)
  10. Year of Construction : 2016
  11. Applicant's letter No : Email dt 25/02/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Pat IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06mtrs	09mtr.	MR
		N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos. ✓	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr each ✓	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases toterrace	01 nos.	01 nos. ✓	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr. ✓	MR
	f. Door Size	01mtr.	01mtr. ✓	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

2/5



05.	Fire Extinguishers			
	• Total numbers	06 nos.	12nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace Level	01 no.	01 no. /	MR
	➤ Discharge of pump	450 lpm	450 lpm /	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/7.

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No.F.6/DFS/MS/2017/1870 dated 27/12/2017 (ground floor). It is recommended to issue fire safety certificate.

*Deepak*  
18/03/2025  
Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (Shd)

*DO(ED)*  
*Deepak*  
18/03/2025

*Dy. Cfo*  
*18/03/25*

*Deep*  
19/03/25

*C.F.O.*  
*18/03/2025*

*Director*  
*21/03/25*

*Director*  
*21/03/25*

*Amr*  
*Shr*

*Sir, fire safety is put up for your kind*  
*Deepak*  
24/03/2025