



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/Industrial/SZ/2025/ 32

Dated: 20/01/2025

To,

The Owner/Occupier/Manager,  
SMS Export, Plot No. D-28,  
Okhla Industrial Area, Phase- I,  
New Delhi-110020.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s SMS Export located at Plot No. D-28, Okhla Industrial Area, Phase- I, New Delhi-110020.**

Sir,

With reference to the letter bearing outdoor diary no. 11239 dated 09.01.2025 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 16.01.2025 in the presence of Mr. Bhupender (HR Assistant) and following shortcomings were observed during the inspection.

1. Semi permanent & temporary construction on terrace floor shall be removed.
2. Standby pump found removed.
3. Fire pumps not in auto mode.
4. Terrace pump is not functional.
5. Overhead tank capacity 15,000 ltrs has been not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)

Director

Delhi Fire Service

**Copy to:-**

The Executive Engineer (Building), MCD, Jal Vihar, Lajpat Nagar, New Delhi-24.