

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 729

Dated: 15/09/2025

To,

The Principal,
Smt. Misri Devi Gyan Niketan,
Shyam Vihar, Najafgarh, New Delhi- 110043.

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o Smt. Misri Devi Gyan Niketan at Shyam Vihar, Najafgarh, New Delhi- 110043.


Sir,

Please refer to your letter No. Nil, dated 28.07.2025, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the school building on dated 03.09.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Yogender Vats, was present and observed that the school building having two blocks, namely A Block is comprised of ground plus one upper floor & B Block is comprised of ground plus two upper floors, and have following shortcomings:-

1. One staircase having width of 1.25 m found provided in B- Block against requirement of two staircases with width of 1.50 m each in B Block.
2. Hose Reels found not provided in B Block.
3. Terrace level fire pump of 450 LPM found not provided in B Block.
4. Overhead water storage tank of 10,000 ltrs. found not provided in B Block.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully


13/09/2025
(Virendra Singh)
Chief Fire Officer
Key.

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.