

✓ 3

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No. F6/DFS/MS/School/2025/ 737

Dated: 18/09/2025

To,

Ms. Nidhi Sharma (Principal),
S.N. Giri Public School,
T-53, Punjabi Basti Baljeet Nagar,
New Delhi.

Sub: Regarding issuance of FSC in r/o S.N. Giri Public School, T-53, Punjabi Basti Baljeet Nagar,
New Delhi.

Sir,

This has reference to your letter no. nil dated 07.08.2025, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 08/09/2025 in the presence of Mr. Nidhi and following shortcomings are observed.

1. Overhead tank is provided of 4000 liter against requirements of 10,000 ltrs.
2. Exit signage is not provided.
3. Total 03 fire extinguishers are provided in the school building, whereas 02 fire extinguishers are required at each floor.

In view of above, fire safety certificate (FSC) cannot be issued at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest under intimation to this department for further consideration in the matter.

Yours faithfully,


16/9/2025

(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.