

c/ky

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No: F6/DFS/MS/SCHOOL/2025/ 840

Dated: 30/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the S. N. Public School, located at RZ-54, Ravi Nagar, Extn. Khayla New Delhi-110018.(School ID-1556313), comprised of ground + 01 upper floor, owner/occupied by S. N. Public School, was issued FSC Vide letter no. F6/DFS/MS/School/WZ/2022/501 dated 09/05/2022. The premises was re-inspected by the officer concerned of this department on 19/06/2025 in the presence of Mrs. Neelam Yadav (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 and found that the building/premises is fit for occupancy class "Educational" Group B with effect from 30/06/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions mentioned below.

Issued on 30/06/2025 at New Delhi by.

(Atul Garg)  
Director

Copy to:-

1. Director of Education, Old Secretariat, New Delhi-110054.
2. The Principal, S. N. Public School, located at RZ-54, Ravi Nagar, Extn. Khayla New Delhi-110018. (School ID-1556313)

**Conditions for the validity of FSC:-**

1. All the fire safety arrangements provided therein shall be maintained in good Working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1.	Name & address of the building	S. N. Public School, located at RZ-54, Ravi Nagar, Extn. Khayla New Delhi-110018.(School ID-1556313)
2.	Type of Occupancy	Educational (Ground + One Upper Floor)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/501 dated 09/05/2022.
5.	Fire Safety directives letter No	DOE Circular 262-362 dated 17/01/2005
6.	Date of inspection	19/06/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Mrs. Neelam Yadav (Principal)
9.	Year of Construction	1994 (As per previous inspection report dated 25/04/2022)
10.	Applicant's letter No.	Outdoor diary No. 1539 dated 13/05/2025.

The said school building comprised of ground + 01 upper floor, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/501 dated 09/05/2022.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1 x 90cm, 1 x 85cm,	MR old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01 mtr	86 cm Provided	MR old case
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	05 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
		30 m	Provided	MR



	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		220 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2500 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

MR 8	Standby power supply	NA	NA	NA
	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked & found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/501 dated 09/05/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

RO/MN  
16/2025

24/06/25

Signature of the Inspecting Officer  
Sarabjeet Singh ADO (MN)

75 MN  
24/06/25

25/6  
CFO - leave  
Director  
25/6/25

Sir, F-7 is put up  
for your kind personal & signature please

Director  
27/6/25