




No. F6/DFS/MS/School/NDZ/2025/1041

Dated: 21/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sneh International School, Junior, Jagriti Enclave, Vikas Marg Extn., Delhi-110092**, building comprised of Basement + Ground + 02 upper floors only, owned/occupied by **Sneh International School** was issued FSC vide letter No. F6/DFS/MS/School/2022/NDZ/731 dated 30/06/2022. The school building was re-inspected by the officer concerned of this department on 13/08/2025 in presence of Mr. **Bunty Kumar (Care Taker)** and found that the said school building have deemed complied with the fire prevention and fire safety requirements provided in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **"Educational Building" (Group - B)** with effect from 21/08/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 21/08/2025 at New Delhi by.


VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi-110002.
2. The Principal, Sneh International School, Junior, Jagriti Enclave, Vikas Marg Extn., Delhi-110092.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
4. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. Basement shall be used as per UBBL.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1	Name & address of the building	Sneh International School, Junior, Jagriti Enclave, Vikas Marg Extn., Delhi-110092.		
2	Building is comprised of	Basement + Ground + 02 upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2022/NDZ/731 dated 30/06/2022		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	13/08/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / (L.N)		
9	Name of the designation of officer from the building side	Mr. Bunty Kumar (Care Taker)		
10	Year of construction	2011		
11	Applicant's letter no.	Outdoor diary no. 4095 dated 24/07/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs.	MR
	B Gate width	4.5 mtrs.	4.5 mtrs.	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			MR
	a Upper floor	01 no.	02 nos.	MR
	b Basement	01 no.	02 nos.	MR
	B Width of staircases			MR
	a Upper floor	1.5 mtrs.	1.60 mtrs.&1.20 mtrs.	MR
	b Basement	1.5 mtrs.	1 no of staircase 1.30 mtr. & 2 exits	MR (Old acceptable)
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	01 no	MR
	E Width of corridor	1.5 mtrs.	1.5 mtrs.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A


5. Fire Extinguisher:				
A	Total numbers	8 nos.	8 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no	Provided	MR
B	Length of hose reel hose	30 m	Provided	MR
C	Nozzle diameter	05 mm	Provided	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	Required	Provided	MR
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	450 LPM	Provided	MR
B	Head of the pump	40 m	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

N/2)


14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	15,000 liters	15,000 liters
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/2022/NDZ/731 dated 30/06/2022, renewal under Rule 35 (6) of the Delhi Fire Service rules 2010, is recommended.


 14/8/2025

Signature of the Inspecting Officer
 Name : Yashwant Singh Meena
 Designation: ADO /Laxmi Naga

D.O/ED

 14.8.2025


Dy CFO (NSZ) 
 18/08/25

C.F.O. 
 18/8/2025

Principal Director

Cfo to Secm.


 19/08/25


 20/8/25

ADD (LH)


P.T.b