



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/GH/NDZ/2025/ 263

Dated: 30/05/2025

To,
The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Solo Guest House located at, C-8,
Greater Kailash-I, New Delhi-110048.**


Sir,

This has reference to MCD application ID No. 2025050207720 dated 02/05/2025 on the subject cited above. In this connection, the premises was re-inspected by the officer concerned of this department on dated 22/05/2025 of the above mentioned Guest House from fire safety point of view in presence of Ms. Sakahi. The Guest House building comprised of Basement, Ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. Fire check door not provided.
2. Carbon-monoxide detectors and panel are not provided.
3. MOFA provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


28/5/2025
CFD

(ATUL GARG)

For DIRECTOR
DELHI FIRE SERVICE

2

e