



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 618

Dated: 07/08/2025

To

Sh. V, K, Sehgal,  
Manager, Sonu Public School,  
RZ-84/1C, Raj Nagar-II,  
Palam Colony, New Delhi-110045

**Sub: Renewal of Fire Safety Certificate in r/o Sonu Public School located at RZ-84/1C, Raj Nagar-II, Palam Colony, New Delhi-110045**


Sir,

This has a reference to your letter No. Nil dated Nil, received in this department vide outdoor diary No. 3452 dated 07/07/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 18/07/2025 from fire safety point of view, in the presence of Smt. Suman (Teacher). During course of inspection, **the shortcomings observed are as below.**

1. The staircase found encroached/blocked with furniture.
2. The hose-reel hose found non-functional.
3. Terrace level fire pump found non-functional.
4. Overhead water storage of 2,500 liters exclusive for firefighting found removed.
5. Exit signage found removed at some places.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
4/8/2025

(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.