



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/EH/SZ/2025/ 247

Dated: 05/06/2025

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: -Regarding grant of Fire Safety Certificate in r/o **M/s Spezia Bistro (Aspen Enterprises)** located at **Property No. 2525, First floor, Hudson Lane, Kingsway Camp, Delhi- 110009.**

Sir,

With reference to the etl.mcdonline application no. 2025051508530 on the subject cited above, it is informed that the said restaurant was inspected by officer concerned of this department on 23.05.2025 in the presence of Mr. Manoj Kumar (Manager) and following shortcomings were observed:

1. Restaurant operational through a main staircase of 1.0 meters, alternate staircase of 1.50 meters was encroached and constructed in ill manner without proper landing.
2. Fire pump having capacity 450 LPM has not provided.
3. Terrace fire tank 10,000 ltrs has not been provided.
4. Combustible furnishing at the exit shall be removed.
5. Exit signages found removed.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

o/c