

cl6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/SZ/2025/ 577

Dated:- 02/12/2025

To

Sh. Sunil Kumar Sinha, Director (HR),
SPMCIL, Corporate Office, at 3rd floor,
Tower G, World Trade Centre, Nauroji Nagar,
New Delhi-110029.

**Sub: Regarding No Objection Certificate in r/o M/s Office Space for SPMCIL,
Corporate office at 3rd floor, Tower G, World Trade Centre Nauroji Nagar, New Delhi.**

Sir,


This has a reference to letter no. SPMCIL-14019(12)/5/2024-Technical-SPMCIL/2076 dated 09.10.2025, on the subject cited above. In this regard, this is to inform you that the site was visited by the officer concerned of this department along with Sh.Himanshu on dated 06.11.2025, to check and verify the compliance of the condition of Fire Safety Certificate in r/o lay out of interior finishing /fit out of furniture and functionality /extension of existing firefighting arrangements. During the visit the following shortcomings were observed.

1. Hydrant line found dry /without water and hydrant coupling & nozzle from hose reel was also found missing.
2. Exit signages are also not provided at conspicuous location.

In view of above, the application for issuances of no objection certificate /FSC for occupy the space in said floor is rejected. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Encl : As above.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer
o/c Delhi Fire Service

Copy to :

1. The Chief General Manager, NBCC of Redevelopment of Nauroji Nagar, New Delhi-29.