

445

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/311

Dated: 26 / 06 / 2025

To

The Executive Engineer (Elect.),
Electrical Division-3/DDA,
Siri Fort, New Delhi-110049

Sub: Regarding Fire Safety Certificate for the occupancy of Sports Complex located at Sector-19, Dwarka, Phase-1, New Delhi.

Sir,

This is with reference to email dated 21.05.2025 received from Id. eeelect3@gmail.com. In this connection, it is to inform you that the premise was inspected by the officers concerned of this department on 11/06/2025 in the presence Sh. Bansilal, A.E (Elect) and Sh. Sidharth Kashyap to verify the compliance of fire safety recommendation issued by this office vide letter No. F.6/DFS/MS/BP/2020/500 dated 29/12/2020. During course of the inspection, the shortcomings observed are as below.

1. Electrical shaft is not found sealed vertically & horizontally.
2. Exit signage in escape route is not yet provided.
3. Lift signage not yet provided.
4. Hose-reel hose & hydrant need to be extended at terrace floor.
5. Smoke venting arrangement at sports halls, needs to be provided.
6. Eating establishment shall apply through online portal for NOC separately.

In view of above, application for issuance of fire safety certificate cannot be considered at this state. You are advised to rectify the shortcomings under intimation to this department and also apply online for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

[Handwritten signature]

Copy to: -

1. The Dy. Director (L&I), Building Section, DDA, Vikas Sadan, INA, New Delhi.