



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 46

Dated: 28/01/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s S.R. Palace Guest House located at Prop. No. 598, Gali Kait Wali, Sangtrashan, Pahar Ganj, New Delhi-110055

Sir,

This has reference to online application No. 2025011400482 dated 14/01/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 15/01/2025 from fire safety point of view, in the presence of Sh. Mangal Singh (Manager) of the guest house. During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose provided found non-functional.
2. 4th Floor used for guest house purpose, despite an affidavit regarding not to use any floor above third floor.

In view of the above, the application for renewal of fire safety certificate is rejected. **It is requested that operation of guest house may be stopped immediately in view of the violation of affidavit dated 11.11.2019 regarding not to use any floor above 3rd floor.** The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Sh. Ram Pratap M/s S.R. Palace Guest House located at Prop. No. 598, Gali Kait Wali, Sangtrashan, Pahar Ganj, New Delhi-110055